



BENGALURU WEST CITY CORPORATION

MEDICAL OFFICER OF HEALTH, MAHALAKSHMI LAYOUT, BENGALURU-86

No: MCH(MLP)/PR/39/26-27

DATE: 30/05/2026

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

It is certified that an inspection team headed by Medical Officer of Health Mahalakshmi Puram, with Senior Health Inspector from Health Department Bengaluru West City Corporation Mahalakshmi Puram inspected the School, **VVS Gandhi Centenary School** on 29/05/2026 found that the school has potable drinking water for students and staff of the institution and having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building.

The above is valid for a period of 2026-27

[Signature] 30/5/26.

Medical Officer of Health
Mahalakshmi Puram Range
Bengaluru West City Corporation

ಅರಸೀಕೆರೆ ವೈದ್ಯಾಧಿಕಾರಿ
ಮಹಾಲಕ್ಷ್ಮಿ ರೇಂಜ್ ವಿಭಾಗ
ಬೆಂಗಳೂರು ಪಶ್ಚಿಮ ನಗರ ಪಾಲಿಕೆ

To
The Principal,
VVS Gandhi Centenary School,
CA Site No.396/A, Rajajinagar,
1st N Block, Bengaluru-560010.

Note: Please Keep Sufficient mosquito repellents especially Electric operated at all working Hours.



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- VVS GANDHI CENTENARY SCHOOL CA SITE NO.396/A, 1ST 'N' BLOCK, RAJAJINAGAR BANGALORE-560010				Report date: 30/03/2026	
				Report Number: 0015	
				Reference: TRF	
				Sample code: 0015	
				Date of Sample collection: 26/03/2026	
				Analysis start date: 27/03/2026	
				Analysis completion date: 27/03/2026	
Sample quantity: 1 Liter					
Sample Particulars: Borewell water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.3	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, µS/cm @25°C Temp	780	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.4	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	490	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO ₃ , mg/l	203.0	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO ₃ , mg/l	208.2	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	51.3	75	200	IS 3025 (Part-40) : 2024
10	Magnesium as Mg, mg/l	19.4	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	86.1	250	1000	IS 3025 (Part-32) : 2025
12	Sulphate as SO ₄ , mg/l	36.9	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.8	1	1.5	APHA 24 th Edition
14	Nitrate as NO ₃ , mg/l	9.6	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2019
Remark: The above given sample conforms to the permissible limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst				Authorized Signatory: Technical Manager: Pavithra B.S	



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---